



QUALITY CERTIFICATE
EN-10204 / 2.2

ICP Valves S.A.U. CERTIFIES that the manufacture of the valves and/or fittings mentioned below has been fulfilled according to the specifications indicated.

PRODUCT DESCRIPTION

Article Bellows Sealed Type Flanged End Globe Valves Figure BGV440 Size: **DN 15 - 25 PN 40**

TYPE MATERIAL

BODY & BONNET	DIN 1.4408	SEAT	DIN 1.4408
TRIM N°	NO. 10#	SPINDLE	DIN 1.4401
DISC	DIN 1.4401	BOLT	A4-70

TEST DESCRIPTION

Testing Std.: EN 12266-1....**YES**..... DIN 3230 Teil..... ICP Std**PS07/I1**.....Other.....
 Hydraulic(barg): Shell 60; Seat 44 / Pneumatic(barg): Shell Seat **6** / Functional.

Results: Satisfactory, seats tightness as per leakage rate A

FOR BODY & BONNET:

CHEMICAL COMPOSITION :									
C	Mn	S	P	Si	Cr	Ni	Mo	Cu	V
0.04	1.3	0.001	0.01	1.2	19.49	9.3	2.12	0.16	-

PHYSICAL PROPERTIES:				
Yield St. 1%	Tensile St.	Elongation	Impact Test ISO V	T. °C
307	557	53	195-204-210	-50

NOTES

Visual and control dimensional results satisfactory.....X...

ICP Valves S.A.U. DECLARES that the ICP valves covered by this certificate have been designed and manufactured in accordance with the requirements of the following European Directives:

- Pressure Equipment Directive 2014/68/EU:

Harmonised and non-harmonised technical standards applied:

- PED: EN 10213:2007, EN 12266:2013, 10222:1998, 10204:2004, 1983:2006, 19:2002, EN ISO 17292:2004, for others, please see the ICP catalogue and ICP Instructions Manual.

Electrical and mechanical accessories are not covered by this declaration and must have their own declaration in order for them to be assembled into ICP valves.

See the corresponding Operating Manual.

Diego Pérez
Quality Manager

Sant Boi de Ll. (Barcelona), 12 February 2024

ICP VALVES, S.A.U.
 Av. Segle XXI, 75 - Pol. Ind. Can Calderon
 08830 Sant Boi de Llobregat
 Barcelona
 Tel. +34 936 548 654





1035

QUALITY CERTIFICATE
EN-10204 / 2.2

ICP Valves S.A.U. CERTIFIES that the manufacture of the valves and/or fittings mentioned below has been fulfilled according to the specifications indicated.

PRODUCT DESCRIPTION

Article Bellows Sealed Type Flanged End Globe Valves Figure BGV440 Size: **DN 32 - 50 PN 40**

TYPE MATERIAL

BODY & BONNET	DIN 1.4408	SEAT	DIN 1.4408
TRIM N°	NO. 10#	SPINDLE	DIN 1.4401
DISC	DIN 1.4401	BOLT	A4-70

TEST DESCRIPTION

Testing Std.: EN 12266-1....**YES**..... DIN 3230 Teil..... ICP Std**PS07/I1**.....Other.....
 Hydraulic(barg): Shell 60; Seat 44 / Pneumatic(barg): Shell Seat **6** / Functional.

Results: Satisfactory, seats tightness as per leakage rate A

FOR BODY & BONNET:

CHEMICAL COMPOSITION :									
C	Mn	S	P	Si	Cr	Ni	Mo	Cu	V
0.04	1.3	0.001	0.01	1.2	19.49	9.3	2.12	0.16	-

PHYSICAL PROPERTIES:				
Yield St. 1%	Tensile St.	Elongation	Impact Test ISO V	T. °C
307	557	53	195-204-210	-50

NOTES

Visual and control dimensional results satisfactory.....X...

ICP Valves S.A.U. DECLARES that the ICP valves covered by this certificate have been designed and manufactured in accordance with the requirements of the following European Directives:

- Pressure Equipment Directive 2014/68/EU:

Harmonised and non-harmonised technical standards applied:

- PED: EN 10213:2007, EN 12266:2013, 10222:1998, 10204:2004, 1983:2006, 19:2002, EN ISO 17292:2004, for others, please see the ICP catalogue and ICP Instructions Manual.

Electrical and mechanical accessories are not covered by this declaration and must have their own declaration in order for them to be assembled into ICP valves.

See the corresponding Operating Manual.

Diego Pérez
Quality Manager

Sant Boi de Ll. (Barcelona), 12 February 2024

ICP VALVES, S.A.U.
 Av. Segle XXI, 75 - Pol. Ind. Can Calderon
 08830 Sant Boi de Llobregat
 Barcelona
 Tel. +34 936 548 654





1035

QUALITY CERTIFICATE

EN-10204 / 2.2

ICP Valves S.A.U. CERTIFIES that the manufacture of the valves and/or fittings mentioned below has been fulfilled according to the specifications indicated.

PRODUCT DESCRIPTION

Article Bellows Sealed Type Flanged End Globe Valves Figure BGV416 Size: **DN 65 - 100 PN 16**

TYPE MATERIAL

BODY & BONNET	DIN 1.4408	SEAT	DIN 1.4408
TRIM N°	NO. 10#	SPINDLE	DIN 1.4401
DISC	DIN 1.4401	BOLT	A4-70

TEST DESCRIPTION

Testing Std.: EN 12266-1....**YES**..... DIN 3230 Teil..... ICP Std**PS07/I1**.....Other.....
 Hydraulic(barg): Shell 24; Seat 18 / Pneumatic(barg): Shell Seat **6** / Functional.

Results: Satisfactory, seats tightness as per leakage rate A

FOR BODY & BONNET:

CHEMICAL COMPOSITION :									
C	Mn	S	P	Si	Cr	Ni	Mo	Cu	V
0.04	1.3	0.001	0.01	1.2	19.49	9.3	2.12	0.16	-

PHYSICAL PROPERTIES:				
Yield St. 1%	Tensile St.	Elongation	Impact Test ISO V	T. °C
307	557	53	195-204-210	-50

NOTES

Visual and control dimensional results satisfactory.....**X**...

ICP Valves S.A.U. DECLARES that the ICP valves covered by this certificate have been designed and manufactured in accordance with the requirements of the following European Directives:

- Pressure Equipment Directive 2014/68/EU:

Harmonised and non-harmonised technical standards applied:

- PED: EN 10213:2007, EN 12266:2013, 10222:1998, 10204:2004, 1983:2006, 19:2002, EN ISO 17292:2004, for others, please see the ICP catalogue and ICP Instructions Manual.

Electrical and mechanical accessories are not covered by this declaration and must have their own declaration in order for them to be assembled into ICP valves.

See the corresponding Operating Manual.

Diego Pérez
Quality Manager

Sant Boi de Ll. (Barcelona), 9 February 2024


 ICP VALVES, S.A.U.
 Av. Segle XXI, 75 - Pol. Ind. Can Calderon
 08830 Sant Boi de Llobregat
 Barcelona
 Tel. +34 936 548 654